




Valve Details

Manufacturer	Good Valve Manufacturer
Model	GV-Manufacturer-80
Design	TOP MOUNTED
Body	Carbon Steel
Serial No.	NA
Tag No.	NA
TestBench SN	0765739

Customer	R AND D
Customer PO	
Site	R AND D SITE
Tank Ref	N/A
Date	18/11/2021 10:26
Test Location	MPF
Engineer	Ewart Cox

Pressure Port

Operated By	WEIGHT LOADED	Tested in accordance with	
Customer Specified Set Point (SP)	20 mBar(g)	ISO28300 & API2000 and Leak Rate @90% of SP	
SP Test Result	±% of SP	Max-Min mBar(g)	SP Test Result
20.19 mBar(g)	5%	19 to 21	PASSED
Leak Test Result	>% of SP	Min mBar(g)	Leak Test Result
20.1 mBar(g) (100.5% of SP)	75%	15	PASSED
Leak rate @90% is 0.0172 CFH (8.1 CCM), (4.25736 M³/Year)			





Vacuum Port			
Operated By	WEIGHT LOADED	Tested in accordance with	
Customer Specified Set Point (SP)	-2.5 mBar(g)	ISO28300 & API2000 and Leak Rate @75% of SP	
SP Test Result	±% of SP	Max-Min mBar(g)	SP Test Result
-2.46 mBar(g)	15%	-2.875 to -2.125	PASSED
Leak Test Result	>% of SP	Min mBar(g)	Leak Test Result
-2.21 mBar(g) (88.4% of SP)	75%	-1.875	PASSED
Leak rate @75% is 0.0267 CFH, (12.6 CCM), (6.62256 M ³ /Year)			

Time (x 0.5 sec)

